

Tel: (011) 805-5002
Fax: (011) 805-5033

Postal Address:
PO Box 7861
Halfway House, 1685

The AAAMSA Performance Test Certificate



NOT TRANSFERABLE

Section A: Particulars of Applicant

Applicant:

Origin Aluminium
P O Box 20971
DURBAN NORTH
4016

Certificate
Number

D0691

Section B: Description of sample submitted for testing

AAAMSA Class Designation:

A1

Applicants' Drawing Reference:

AAAMSA 2

Product

Vertical Slider

Overall Dimensions:

900mm w x 1200mm h

Glass Type:

Glass Thickness:

4mm clear

Glazing Gaskets:

PVC Channels

Weather Seals:

Fin Ple


Hardware:

Pin Catch

Joint Sealant:

Silicone

Dimensional sketch of Sample



Comments by Testing Authority

Section C: Testing

Performance Test	Test Conditions	Measured Result	Allowed Result
1. Air Infiltration	75 Pa	0.19 l/sec/m ²	2 l/sec/m ²
2. Positive Pressure	1000 Pa	2.43 mm	5.14 mm
3. Negative Pressure	1000 Pa	2.43 mm	5.14 mm
4. Water Penetration	200 Pa	No permanent	No Leaks
5. Structural Pressure	1500 Pa	deformation	No Permanent deformation
6. Operating Forces:			
To start movement		50N	180N
To sustain Movement		30N	120N

Section D: Certification

Testing Authority:

(Stamp) Test Facility, Durban
R Saunderson PrEng
Reg. No. 703219

Validated by AAAMSA:

(Stamp) AAAMSA
PO Box 7861
Halfway House
1685

Date of issue: 22 March 2009

Date of Validation: 26 March 2009

Signed: Mr. R Saunderson

Signed:

Designation: Testing Officer

Designation: Executive Director

NOTE: THIS CERTIFICATE IS ISSUED SUBJECT TO THE CONDITIONS ON THE REVERSE SIDE